

**UK DECLARATION OF CONFORMITY**

We:

<b>Tungsram Operations Kft.</b>	
Registered office:	<b>1044 Budapest, Váci út 77. Hungary</b>
Contact address:	<b>1044 Budapest, Váci út 77. Hungary</b>

as manufacturer, declare under our sole responsibility that the product:

Product family: **Emergency Bulkhead; Emergency Exit Sign**

Product identification: Listed in Appendix

Manufactured in: **China**

to which this declaration relates is in conformity with the relevant UK statutory requirements. References to the relevant designated standards used or references to the other technical specifications in relation to which conformity is declared are as follows::

**UK DECLARATION OF CONFORMITY****ELECTRICAL AND PHOTOBIOLOGICAL SAFETY**

<b>Number, version, year of issue</b>	<b>Title</b>	<b>Comment</b>
EN 60598-2-22:2014, EN 60598-2-22:2014/AC:2015, EN 60598-2-22:2014/AC:2016-05, EN 60598-2-22:2014/AC:2016-09	Luminaires - Part 2-22: Particular requirements - Luminaires for emergency lighting	
EN 60598-1:2015, EN 60598-1:2015/AC:2015, EN 60598-1:2015/AC:2016, EN 60598-1:2015/AC:2017-05, EN 60598-1:2015/A1:2018	Luminaires - Part 1: General requirements and tests	
EN 60598-2-1:1989	Luminaires - Part 2: Particular requirements - Section 1: Fixed general purpose luminaires	for Fixed type
EN 60598-2-2:2012	Luminaires - Part 2-2: Particular requirements - Recessed luminaires	for Recessed type
EN 62493:2015, IEC 62493:2015	Assessment of lighting equipment related to human exposure to electromagnetic fields	

therefore it complies with the provisions of the following UK Statutory Instrument

**UK S.I. 2016/1101.**

**UK DECLARATION OF CONFORMITY****ELECTROMAGNETIC COMPATIBILITY**

Number, version, year of issue	Title
EN 55015:2013+A1:2015	Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment
EN 61000-3-2:2014	Electromagnetic compatibility (EMC) - Part 3-2: Limits - Limits for harmonic current emissions (equipment input current <= 16 A per phase)
EN 61000-3-3:2013	Electromagnetic compatibility (EMC) - Part 3-3: Limits - Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current <= 16 A per phase and not subject to conditional connection
EN 61547:2009	Equipment for general lighting purposes - EMC immunity requirements

therefore it complies with the provisions of the following UK Statutory Instrument

**UK S.I. 2016/1091.**

**ROHS**

Number, version, year of issue	Title
EN IEC 63000:2018	Technical documentation for the assessment of electrical and electronic products with respect to the restriction of hazardous substances

therefore it complies with the provisions of the following UK Statutory Instrument:

**UK S.I. 2012/3032.**

**UK DECLARATION OF CONFORMITY**


 (signature)

Lantos Ferenc (name)

Chief  
Technology and  
PM Officer (Title)

2021-11-29 (date) (YYYY-MM-DD)

Hungary (Country)

 (signature)

Dr Pilter  
József Zoltán (name)

Regulatory  
Affairs Manager (Title)

2021-11-29 (date) (YYYY-MM-DD)

Hungary (Country)

**UK DECLARATION OF CONFORMITY**

## Appendix

Brand : Tungsram (*TU*)

<b>SKU or Internal ref#</b>	<b>Model identification (Monogramming)</b>	<b>Description</b>
A-1022482-01	Emergency Exit G1 TU 3 LI S SM	Fixed type
A-1022484-01	Emergency Exit G1 TU 3 LI S RM	Recessed type
A-1022485-01	Emergency Exit G1 TU 3 LI S WM	Fixed type
A-1022486-01	Emergency Bulkhead G1 TU 3 NI S WM	Fixed type